

EPR, 105C, TAPE SHIELD, 133% INSULATION, COPPER, THREE CONDUCTORS PER FEEDER										
CONDUCTOR SIZE	GROUND SIZE (1)	APPROX. O.D. INCHES (2)	APPROX. WEIGHT LBS/1000' (2)	AMPACITY IN DUCT (3)	MIN. BENDING RADII INCHES (4)	CONDUIT SIZE (5)	JAM RATIO (6)	PERCENT FILL (7)	MAX PULLING TENSION LBS (8)	MAX SIDEWALL PRESSURE LB-FT
BICC CABLE										
2 AWG	6 AWG	1.01	685	115	12.1	6	5.94	8.6%	1,060	500
2/0 AWG	4 AWG	1.13	979	165	13.6	6	5.31	10.8%	2,130	500
4/0 AWG	2 AWG	1.23	1299	205	14.8	6	4.88	13.0%	3,380	500
350 KCMIL	4/0 AWG	1.41	1875	265	16.9	6	4.26	16.9%	5,600	500
500 KCMIL	4/0 AWG	1.53	2440	310	18.4	6	3.92	19.9%	6,500	500
750 KCMIL (9)	4/0 AWG	1.72	3378	375	20.6	6	3.49	25.0%	6,500	500
KERITE CABLE										
2 AWG	6 AWG	1.06	725	115	12.7	6	5.66	9.5%	1,062	675
2/0 AWG	4 AWG	1.19	1021	165	14.3	6	5.04	11.9%	2,130	675
4/0 AWG	2 AWG	1.29	1344	205	15.5	6	4.65	14.2%	3,386	675
350 KCMIL	4/0 AWG	1.47	1916	265	17.6	6	4.08	18.4%	5,600	675
500 KCMIL	4/0 AWG	1.60	2478	310	19.2	6	3.75	21.5%	8,000	675
750 KCMIL (9)	4/0 AWG	1.87	3533	375	22.4	6	3.21	29.5%	12,000	675
OKONITE CABLE										
2 AWG	6 AWG	1.00	670	115	12.0	6	6.00	8.4%	1,062	500
2/0 AWG	4 AWG	1.11	955	165	13.3	6	5.41	10.4%	2,130	500
4/0 AWG	2 AWG	1.21	1265	205	14.5	6	4.96	12.5%	3,386	500
350 KCMIL	4/0 AWG	1.37	1810	265	16.4	6	4.38	16.0%	5,600	500
500 KCMIL	4/0 AWG	1.49	2355	310	17.9	6	4.03	18.8%	8,000	500
750 KCMIL (9)	4/0 AWG	1.73	3360	375	20.8	6	3.47	25.3%	10,000	500
2 AWG	6 AWG	NOT RECOMMENDED, CONSIDER TRIPLEX -->				4	4.00	19.0%		
2/0 AWG	4 AWG					4	3.60	23.4%		
4/0 AWG	2 AWG					4	3.31	28.2%		
350 KCMIL	4/0 AWG					4	2.92	36.0%		

- NOTES:
- (1) BARE COPPER FOR STEEL OR PVC CONDUIT. INSULATED WIRE FOR ALUMINUM CONDUIT.
- (2) BASED ON BICC UNIBLEND POWER CABLE P/N 17031-130200, -135200, -135400, -136200, -136500, -137000;  
KERITE POWER CABLE TYPE MV-105 CAT. NO. 102C15-C4400, 121C15-, 141C15-, 135C15-, 150C15-, 175C15-;  
OKONITE TYPE MV-105 133% INSULATION CABLE CAT # 115-23-3111, -3117, -3121, -3127, -3131, -3135.
- (3) 2002 NEC TABLE 310.77 AND FIGURE 310.60 DETAIL 3, 30" MAX. TO TOP OF DUCT, 7-1/2" CENTERS, 6 CIRCUITS.
- (4) 12 X CABLE OD PER 2002 NEC 300.34 FOR SHIELDED CONDUCTORS
- (5) 6 INCH DUCT STANDARD FOR MAIN DUCTBANKS. 4 INCH DUCT STANDARD FOR LOAD SPECIFIC FEEDERS <200A.
- (6) CONDUIT ID/CABLE OD. 2.8 TO 3.2 = CRITICAL AREA TO BE AVOIDED
- (7) BARE GROUND CONDUCTOR ASSUMED.
- (8) T = 0.008 X 2 CONDUCTORS (CRADLED POSITION ASSUMED) X CIRCULAR MILLS. ALL MANUFACTURER'S USE SOME VARIATION OF THIS FORMULA. BICC'S VALUES ARE FROM A TABLE. OKONITE LIMITS MAXIMUM TENSION TO 10,000 LBS. SIDEWALL PRESSURE IS USUALLY THE LIMITING FACTOR.
- (9) 750KCMIL TO BE USED ON AN EXCEPTION BASIS ONLY

R E V I S I O N S				PROJECT MANAGER: — PROJECT ENGINEER: — DESIGN ENGINEER: — DRAFTER: — SCALE: NONE DATE: — CHECKED/APPROVED BY: —	<div>Port of Seattle</div> <div>SEA-TAC INTERNATIONAL AIRPORT</div> <div>PROJECT: F&amp;I STANDARD DETAILS</div> <div>SHEET TITLE: STANDARD STIA 12.47KV FEEDER AND DUCT SIZES</div>	WORK PROJECT NO.		
NO.	DATE	BY	DESCRIPTION			CONSULTANT'S NO.		
1	03/01/2019	KDM	2019 F&I STANDARD DETAILS					
2	03/01/2020	KDM	2020 F&I STANDARD DETAILS					
						PORT OF SEATTLE NO.		
						260513	01	