

TRANSFORMER NAMEPLATE SCHEDULE

RATINGS:

kVA: 1500      PHASE: 3      FREQ: 60 HZ  
TEMP RISE: 65°C RISE 0A      kV BIL: 95  
PRIMARY VOLTS: 12.47kV      ☒ DELTA    ☐ GND WYE    ☐ WYE  
SECONDARY VOLTS: 480Y/277      IMPEDANCE: 5.75%  
WINDINGS: ALUMINUM      FLUID: MINERAL OIL

PROJECT DATA:

ENGINEER: \_\_\_\_\_  
POS PSA NO: \_\_\_\_\_  
POS W.O. NO: \_\_\_\_\_  
REF DWG: \_\_\_\_\_  
CONTRACTOR: \_\_\_\_\_  
CONTRACT NO: \_\_\_\_\_  
DATE COMPLETED: \_\_\_\_\_  
EQUIP MFR: \_\_\_\_\_  
LOCATION: \_\_\_\_\_  
REF G.O. NO: \_\_\_\_\_

SEC WIRE COLOR CODES:

AØ – BROWN  
BØ – ORANGE  
CØ – YELLOW  
NEUT – WHITE  
GND – GREEN

ISOLATION FUSE LINK: \_\_\_\_\_  
CURRENT LIMITING FUSE: \_\_\_\_\_  
LOAD SENSING FUSE: \_\_\_\_\_

FIELD/DESIGN EVALUATION:

BY: \_\_\_\_\_  
DATE: \_\_\_\_\_

R E V I S I O N S					PROJECT MANAGER: — PROJECT ENGINEER: — DESIGN ENGINEER: — DRAFTER: — SCALE: AS NOTED DATE: — CHECKED/APPROVED BY: —	<div><div>Port of Seattle</div><div>SEA-TAC INTERNATIONAL AIRPORT</div><div>PROJECT: F&amp;I STANDARD DETAILS</div><div>SHEET TITLE: TRANSFORMER NAMEPLATE SCHEDULE</div></div>	WORK PROJECT NO.	
NO.	DATE	BY	DESCRIPTION				CONSULTANT'S NO.	
1	03/01/2019	KDM	2019 F&I STANDARD DETAILS					
2	03/01/2020	KDM	2020 F&I STANDARD DETAILS					
					PORT OF SEATTLE NO.			
					261200	02		